

| NO 626/2011 &EN 14511 and NO 206/2012 & EN 14825: 2016 |                    |  |                 |         |
|--|--------------------|--|-----------------|---------|
| Clause   | Requirement - Test |  | Result - Remark | Verdict |

**Appendix I: information according to clause 3 of NO 206/2012 ANNEX I , for air conditioners, except single duct and double duct air conditioners**

| Function (indicate if present)   |          |       |      | Only for heating mode, if applicable  |        |       |      |
|--|----------|-------|------|---|--------|-------|------|
| Cooling  | Y        |       |      | Average(mandatory)  | Y      |       |      |
| Heating  | Y        |       |      | Warmer(if designed)   | Y      |       |      |
|  |          |       |      | Colder(if designed)   | Y      |       |      |
| Item   | Symbol   | Value | Unit | Item  | Symbol | Value | Unit |
| Design load  |          |       |      | Seasonal efficiency   |        |       |      |
| Cooling  | Pdesignc | 2.5   | kW   | Cooling   | SEER   | 6.1   | —    |
| Heating/average  | Pdesignh | 2.6   | kW   | Heating/average   | SCOP/A | 4.0   | —    |
| Heating/warmer   | Pdesignh | 2.8   | kW   | Heating/warmer  | SCOP/W | 5.1   | —    |
| Heating/colder   | Pdesignh | 2.7   | kW   | Heating/colder  | SCOP/C | 3.2   | —    |
| Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj            |          |       |      | Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj              |        |       |      |
| Item   | Symbol   | Value | Unit | Item  | Symbol | Value | Unit |
| Tj=35°C  | Pdc      | 2.69  | kW   | Tj=35°C   | EERd   | 3.30  | —    |
| Tj=30°C  | Pdc      | 1.89  | kW   | Tj=30°C   | EERd   | 4.80  | —    |
| Tj=25°C  | Pdc      | 1.19  | kW   | Tj=25°C   | EERd   | 7.85  | —    |
| Tj=20°C  | Pdc      | 1.00  | kW   | Tj=20°C   | EERd   | 11.29 | —    |
| Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj |          |       |      | Declared coefficient of performance(*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj |        |       |      |
| Tj=-7°C  | Pdh      | 2.31  | kW   | Tj=-7°C   | COPd   | 2.74  | —    |
| Tj=2°C   | Pdh      | 1.41  | kW   | Tj=2°C  | COPd   | 4.05  | —    |
| Tj=7°C   | Pdh      | 0.92  | kW   | Tj=7°C  | COPd   | 4.84  | —    |
| Tj=12°C  | Pdh      | 0.87  | kW   | Tj=12°C   | COPd   | 5.97  | —    |
| Tj=operating limit   | Pdh      | 2.12  | kW   | Tj=operating limit  | COPd   | 2.54  | —    |
| Tj=bivalent temperature  | Pdh      | 2.31  | kW   | Tj=bivalent temperature   | COPd   | 2.74  | —    |

| NO 626/2011 &EN 14511 and NO 206/2012 & EN 14825: 2016 |                    |  |  |                 |  |         |  |
|--|--------------------|--|--|-----------------|--|---------|--|
| Clause   | Requirement - Test |  |  | Result - Remark |  | Verdict |  |

| Function (indicate if present)  |        |       |      | Only for heating mode, if applicable   |        |       |      |
|---|--------|-------|------|--|--------|-------|------|
| Cooling   | Y      |       |      | Average(mandatory)   | Y      |       |      |
| Heating   | Y      |       |      | Warmer(if designed)  | Y      |       |      |
|   |        |       |      | Colder(if designed)  | Y      |       |      |
| Item  | Symbol | Value | Unit | Item   | Symbol | Value | Unit |
| Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj |        |       |      | Declared coefficient of performance(*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj |        |       |      |
| Tj=2°C  | Pdh    | 2.93  | kW   | Tj=2°C   | COPd   | 2.48  | —    |
| Tj=7°C  | Pdh    | 1.83  | kW   | Tj=7°C   | COPd   | 4.94  | —    |
| Tj=12°C   | Pdh    | 0.87  | kW   | Tj=12°C  | COPd   | 5.98  | —    |
| Tj=operating limit  | Pdh    | 2.93  | kW   | Tj=operating limit   | COPd   | 2.48  | —    |
| Tj=bivalent temperature   | Pdh    | 2.93  | kW   | Tj=bivalent temperature  | COPd   | 2.48  | —    |
| Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj |        |       |      | Declared coefficient of performance(*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj |        |       |      |
| Tj=-7°C   | Pdh    | 1.65  | kW   | Tj=-7°C  | COPd   | 2.97  | —    |
| Tj=2°C  | Pdh    | 0.99  | kW   | Tj=2°C   | COPd   | 3.62  | —    |
| Tj=7°C  | Pdh    | 0.68  | kW   | Tj=7°C   | COPd   | 4.46  | —    |
| Tj=12°C   | Pdh    | 0.87  | kW   | Tj=12°C  | COPd   | 5.96  | —    |
| Tj=operating limit  | Pdh    | 1.98  | kW   | Tj=operating limit   | COPd   | 1.86  | —    |
| Tj=bivalent temperature   | Pdh    | 2.12  | kW   | Tj=bivalent temperature  | COPd   | 2.54  | —    |
| Tj=-15°C  | Pdh    | --    | kW   | Tj=-15°C   | COPd   | --    | —    |
| Bivalent temperature  |        |       |      | Operating limit temperature  |        |       |      |
| Heating/Average   | Tbiv   | -7    | °C   | Heating/Average  | Tol    | -10   | °C   |
| Heating/Warmer  | Tbiv   | 2     | °C   | Heating/Warmer   | Tol    | 2     | °C   |
| Heating/Colder  | Tbiv   | -10   | °C   | Heating/Colder   | Tol    | -20   | °C   |
| Cycling interval capacity   |        |       |      | Cycling interval efficiency  |        |       |      |
| for cooling   | Pcycc  | x,x   | kW   | for cooling  | EERcyc | x,x   | —    |
| for heating   | Pcych  | x,x   | kW   | for heating  | COPcyc | x,x   | —    |
| Degradation co-efficient cooling (**)   | Cdc    | 0.25  | —    | Degradation co-efficient heating (**)  | Cdh    | 0.25  | —    |

| NO 626/2011 &EN 14511 and NO 206/2012 & EN 14825: 2016 |                    |                 |         |
|--|--------------------|-----------------|---------|
| Clause   | Requirement - Test | Result - Remark | Verdict |

| Function (indicate if present)   |                  |                 |   | Only for heating mode, if applicable |                 |            |                       |  |  |  |  |  |
|--|------------------|-----------------|---|--------------------------------------|-----------------|------------|-----------------------|--|--|--|--|--|
| Cooling  | Y                |                 |   | Average(mandatory)                   | Y               |            |                       |  |  |  |  |  |
| Heating  | Y                |                 |   | Warmer(if designed)                  | Y               |            |                       |  |  |  |  |  |
|  |                  |                 |   | Colder(if designed)                  | Y               |            |                       |  |  |  |  |  |
| Item   | Symbol           | Value           | Unit  | Item                                 | Symbol          | Value      | Unit                  |  |  |  |  |  |
| Electric power input in power modes other than 'active mode'   |                  |                 |   | Annual electricity consumption       |                 |            |                       |  |  |  |  |  |
| Off mode   | P <sub>OFF</sub> | 0.00427         | kW  | Cooling                              | Q <sub>CE</sub> | 143        | kWh/a                 |  |  |  |  |  |
| Standby mode   | P <sub>SB</sub>  | 0.00427         | kW  | Heating/Average                      | Q <sub>HE</sub> | 910        | kWh/a                 |  |  |  |  |  |
| Thermostat-off mode  | P <sub>TO</sub>  | 0.00483/0.00912 | kW  | Heating/Warmer                       | Q <sub>HE</sub> | 769        | kWh/a                 |  |  |  |  |  |
| Crankcase heater mode  | P <sub>CK</sub>  | 0               | kW  | Heating/Colder                       | Q <sub>HE</sub> | 1772       | kWh/a                 |  |  |  |  |  |
| Capacity control (indicate one of three options)   |                  |                 |   | Other items                          |                 |            |                       |  |  |  |  |  |
| fixed  | N                |                 |   | Sound power level (indoor/outdoor)   | L <sub>WA</sub> | (55/61)    | dB(A)                 |  |  |  |  |  |
| staged   | N                |                 |   | Global warming potential             | GWP             | 675        | kgCO <sub>2</sub> eq. |  |  |  |  |  |
| variable   | Y                |                 |   | Rated air flow (indoor/outdoor)      | —               | (660/2200) | m <sup>3</sup> /h     |  |  |  |  |  |
| Contact details for obtaining more information   |                  |                 | Gree Electric Appliances Inc. of Zhuhai<br>West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070<br>Email: greerzsykt@cn.gree.com |                                      |                 |            |                       |  |  |  |  |  |
| (*) For staged capacity units, two values divided by a slash ('/') will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of the unit.     |                  |                 |   |                                      |                 |            |                       |  |  |  |  |  |
| (**) If default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.                        |                  |                 |   |                                      |                 |            |                       |  |  |  |  |  |
| For units with capacity control marked 'staged', two values for the highest and lowest, noted 'hi/lo' divided by a slash ('/') will be declared in each box under 'Declared capacity'. |                  |                 |   |                                      |                 |            |                       |  |  |  |  |  |