



# PRODUCT PERFORMANCE RATING

Document ID 112520201739-14724961

Issued on 25 November 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.04.002**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	MIDEA
Range	BLANC R32
Product référence	MOX133-12HFN8-QRD0GW/MSMABU-12HRDNX-QRD0FGW(GA)

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
-	-	-	Hungary

FEATURE	VALUE	UNIT
<b>STANDARD COOLING/COOLING PL COND A</b>		
Pc	3.60	kW
Pec	1.24	kW
EER	2.90	



# PRODUCT PERFORMANCE RATING

Document ID 112520201739-14724961

Issued on 25 November 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.04.002**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>STANDARD HEATING</b>		
Ph	3.81	kW
Peh	1.09	kW
COP	3.50	

FEATURE	VALUE	UNIT
<b>ACOUSTIC</b>		
LwO env	63	dB(A)
LwI1 env	55	dB(A)

FEATURE	VALUE	UNIT
<b>COOLING PL CONDB</b>		
Pc @ 30°C	2.44	kW
EER @ 30°C	4.55	



# PRODUCT PERFORMANCE RATING

Document ID 112520201739-14724961

Issued on 25 November 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.04.002**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL CONDC</b>		
Pc @ 25°C	1.65	kW
EER @ 25°C	6.99	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDD</b>		
Pc @ 20°C	1.07	kW
EER @ 20°C	11.96	

FEATURE	VALUE	UNIT
<b>SEASONAL EFFICIENCY IN COOLING</b>		
Pdesignc	3.60	kW
SEER	6.10	
Qce	206.53	kWh/annum
SEER Class	A++	



# PRODUCT PERFORMANCE RATING

Document ID 112520201739-14724961

Issued on 25 November 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.04.002**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL CONDA</b>		
Ph @ -7°C	2.39	kW
COP @ -7°C	2.80	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDB</b>		
Ph @ +2°C	1.46	kW
COP @ 2°C	4.07	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDC</b>		
Ph @ +7°C	0.95	kW
COP @ +7°C	4.80	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDD</b>		
Ph @ +12°C	1.11	kW
COP @ +12°C	6.07	



# PRODUCT PERFORMANCE RATING

Document ID 112520201739-14724961

Issued on 25 November 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.04.002**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING AVERAGE CLIMATE</b>		
Pdesignh	2.70	kW
SCOP	4.00	
SCOP Class	A+	
Qhe	945.38	kWh/annum

FEATURE	VALUE	UNIT
<b>BIVALENT POINT</b>		
Tbiv	-7	°C
COP @ Tbiv	2.80	
Ph TBiv	2.39	kW

FEATURE	VALUE	UNIT
<b>TOL RUNING TEST</b>		
TOL	-10.00	°C
COP @ TOL	2.63	
Ph @ TOL	2.02	kW



# PRODUCT PERFORMANCE RATING

Document ID 112520201739-14724961

Issued on 25 November 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.04.002**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>POFFC</b>		
Poff	1.20	W

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psb	1.20	W

FEATURE	VALUE	UNIT
<b>PTOC</b>		
Pto	18.00	W

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Capacity Control	variable	
Main Power Supply	230-1-50	
Refrigerant	R32	
Refr. Line	5m	m
Mounting	wall-mounted	



# PRODUCT PERFORMANCE RATING

Document ID **112520201739-14724961**

Issued on 25 November 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.04.002**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>EDIBATEC_H</b>		
Nb Taval Chauffage	1	
Nb Tamont Chauffage	1	

FEATURE	VALUE	UNIT
<b>EDIBATEC_C</b>		
Nb Taval Froid	1	
Nb Tamont Froid	1	